

DSPJ BACAU  
 LABORATOR MICROBIOLOGIA APEI - inregistrat M.S. nr. 450/17.05.2017  
 LABORATOR CHIMIA APEI - inregistrat M.S. nr. 412/25.10.2016  
 Operator de date cu caracter personal nr.14781  
 NR. BULETIN..... 968.....DATA... 10.04.2019.....

### BULETIN DE ANALIZA

Provenienta probei/ Solicitant PRIMARIA CETEA-VECHTE-ALIMENTARE CU APA CETEA-VECHTE  
 - FEIER STARE: ROBINET STARE.....Sursa.....  
 Data recoltarii... 10.04.2019.....Ora recoltarii.....Ora analizarii probei.....  
 Recoltarea efectuata de: Dr. Mihai Ciuc.....

### ANALIZA BACTERIOLOGICA

PARAMETRU ANALIZAT	NORMA METODOLOGICA	VALOARE ADMISA conform Lg. 458/2002 republicata in 2011	VALORI ALE PROBEI ANALIZATE
Numar de colonii la 22 grade Celsius/ml	SR EN ISO 6222/2004	Nici o modificare anormala	—
Numar de colonii la 37 grade Celsius/ml	SR EN ISO 6222/2004	Nici o modificare anormala	—
Bacterii coliforme/100 ml	ISO 9308-1/2014	0	—
Escherichia coli/100ml	ISO 9308-1/2014	0	0
Enterococi/100 ml	ISO/FDIS 7899-2/2000	0	0

Aprobat,  
 Manager tehnic

DR. MIHAI CIUC  
 Medic specialist  
 medicină de laborator  
 Cod 90301

Verificat,  
 Responsabil analiza

PRISACARIU CARMEN  
 Biolog specialist bacteriolog  
 Cod: 340132

### ANALIZA FIZICO-CHIMICA

PARAMETRU ANALIZAT	Unitati de masura	NORMA METODOLOGICA	VALOARE ADMISA conform Lg. 458/2002 si modificarile ulterioare	VALORI ALE PROBEI ANALIZATE
pH	unitati pH	SR ISO 10523/2012	6.5 - 9.5	—
Turbiditate	UNT	SR EN ISO7027/2001	max. 5	—
Amoniu	mg/l	SR ISO 7150-1/2001	max. 0.5	—
Nitriti	mg/l	SR ISO 26777/2006	max. 0.1/max. 0.5	—
Nitrati	mg/l	SR ISO 7890-3/2000	max. 50	—
Cloruri	mg/l	SR ISO 9297/2001	max. 250	—
Indice de permanganat	mg O <sub>2</sub> /l	SR EN ISO 8467/2001	max. 5	—
Clor liber rezidual total	mg/l	STAS 6364-78	min. 0.1/max. 0.5	0,05 + 0
Suma de calciu si magneziu	grade germane	SR ISO 6059/2008	min. 5	—
Aluminiu	micrograme/l	Method 8326	max. 200	—
Fier	micrograme/l	Method 8008	max. 200	—
Mangan	micrograme/l	Method 8149	max.50	—

Aprobat,  
 Chimist coordonator

Cod: BA-18-04

ALINA KOVAC  
 chimist coordonator principal  
 Cod 903034

Verificat,  
 Responsabil analiza

Editia: 4/1 Revizia 0/3 Pag 1 din 1